

板坂地区

(放流水質)

令和5年度

月	pH	SS mg/ℓ	COD mg/ℓ		BOD mg/ℓ	Cl ⁻ mg/ℓ	T-N mg/ℓ		T-P mg/ℓ		大腸 個/mℓ
排水基準値	5.8- 8.6	90 (70)	50 (40)		25 (20)		120 (60)		16 (8)		3000
4	7.5	6.0	25.0	22.0	11.0	32.0	34.0	23.0	3.40	2.10	1未満
5	7.2	3.0	13.0	18.0	5.0	17.0	11.0	21.0	1.20	2.30	1未満
6	7.2	2.0	17.0	25.0	6.1	24.0	16.0	25.0	1.90	2.90	1未満
7	7.4	3.0	16.0	23.0	5.4	26.0	23.0	25.0	2.30	2.70	1未満
8	7.5	2.0	18.0	15.0	5.0	32.0	32.0	25.0	3.40	2.70	1未満
9	7.4	1.0	16.0	14.0	3.6	28.0	28.0	26.0	2.60	2.50	1未満
10	7.5	3.0	18.0	17.0	4.8	32.0	30.0	27.0	3.40	2.90	1未満
11	7.3	4.0	19.0	15.0	11.0	33.0	30.0	22.0	3.10	2.60	1未満
12	7.3	4.0	19.0	20.0	8.6	31.0	27.0	28.0	3.00	3.40	1未満
1	7.6	4.0	28.0	23.0	9.9	35.0	35.0	32.0	3.30	3.30	1未満
2											
3											
平均	7.4	3.2		19.1	7.0	29.0		26.0		2.75	1.0
最大	7.6	6.0		28.0	11.0	35.0		35.0		3.40	1.0
最小	7.2	1.0		13.0	3.6	17.0		11.0		1.20	1.0

板坂地区

(流入水質)

月	pH	SS mg/ℓ	COD mg/ℓ	BOD mg/ℓ	T-N mg/ℓ	T-P mg/ℓ
5	7.3	99.0	67.0	69.0	25.0	2.6
8	7.3	150.0	100.0	170.0	43.0	4.7
10	7.3	140.0	100.0	120.0	40.0	3.9
2						
平均	7.3	129.7	89.0	119.7	36.0	3.7
最大	7.3	150.0	100.0	170.0	43.0	4.7
最小	7.3	99.0	67.0	69.0	25.0	2.6

放流基準値

pH	5.8以上8.6以下	—
SS	50以下	mg/ℓ
COD	40以下	mg/ℓ
BOD	20以下	mg/ℓ
Cl ⁻	—	mg/ℓ
T-N	60以下	mg/ℓ
T-P	8以下	mg/ℓ
大腸菌群数	3000以下	個/mℓ

鍛冶屋地区 (放流水質)

令和5年度

月	pH	SS mg/ℓ	COD mg/ℓ				BOD mg/ℓ	Cl ⁻ mg/ℓ	T-N mg/ℓ				T-P mg/ℓ			大腸 個/mℓ	
排水基準値	5.8- 8.6	90 (70)	50 (40)				25 (20)		120 (60)				16 (8)			3000	
4	7.4	2.0	25.0	22.0	23.0	26.0	11.0	34.0	31.0	26.0	24.0	30.0	3.10	2.70	2.30	3.10	1未満
5	7.4	1.0	16.0	26.0	25.0	25.0	6.3	23.0	17.0	27.0	26.0	31.0	1.60	2.80	2.90	3.20	1未満
6	7.3	2.0	23.0	22.0	26.0	23.0	11.0	27.0	22.0	27.0	26.0	28.0	2.30	2.80	2.90	2.70	1未満
7	7.4	2.0	22.0	22.0	31.0	25.0	4.7	34.0	28.0	26.0	26.0	29.0	3.00	2.70	3.10	3.00	1未満
8	7.4	1.0	21.0	18.0	21.0	23.0	6.8	37.0	29.0	27.0	28.0	27.0	3.30	2.80	3.10	3.10	1未満
9	7.5	1.0	21.0	17.0	22.0	20.0	2.5	33.0	28.0	28.0	28.0	28.0	2.80	3.10	3.10	3.20	1未満
10	7.5	2.0	20.0	22.0	19.0	20.0	2.9	34.0	29.0	27.0	25.0	29.0	3.30	3.10	3.00	3.30	1未満
11	7.4	3.0	21.0	19.0	17.0	21.0	5.1	35.0	28.0	25.0	26.0	28.0	2.80	3.60	3.10	2.90	1未満
12	7.4	3.0	20.0	23.0	21.0	24.0	6.6	35.0	29.0	29.0	29.0	29.0	3.10	2.80	3.50	2.90	1未満
1	7.6	3.0	27.0	29.0	29.0	32.0	8.8	38.0	34.0	31.0	33.0	32.0	3.40	3.20	3.60	3.50	1未満
2																	
3																	
平均	7.4	2.0					22.7	6.6	33.0				27.8			3.00	1.0
最大	7.6	3.0					32.0	11.0	38.0				34.0			3.60	1.0
最小	7.3	1.0					16.0	2.5	23.0				17.0			1.60	1.0

鍛冶屋地区 (流入水質)

月	pH	SS mg/ℓ	COD mg/ℓ	BOD mg/ℓ	T-N mg/ℓ	T-P mg/ℓ
5	7.3	99.0	65.0	75.0	26.0	2.8
8	7.1	160.0	92.0	130.0	33.0	3.5
10	7.0	130.0	130.0	150.0	43.0	4.9
2						
平均	7.1	129.7	95.7	118.3	34.0	3.7
最大	7.3	160.0	130.0	150.0	43.0	4.9
最小	7.0	99.0	65.0	75.0	26.0	2.8

放流基準値		
pH	5.8以上8.6以下	—
SS	50以下	mg/ℓ
COD	40以下	mg/ℓ
BOD	20以下	mg/ℓ
Cl ⁻	—	mg/ℓ
T-N	60以下	mg/ℓ
T-P	8以下	mg/ℓ
大腸菌群数	3000以下	個/mℓ

余田地区 (放流水質)

令和5年度

月	pH	SS mg/ℓ	COD mg/ℓ				BOD mg/ℓ	Cl ⁻ mg/ℓ	T-N mg/ℓ				T-P mg/ℓ				大腸 個/mℓ
排水基準値	5.8- 8.6	90 (70)	50 (40)				25 (20)		120 (60)				16 (8)				3000
4	7.4	2.0	27.0	23.0	23.0	32.0	10.0	34.0	31.0	23.0	21.0	30.0	3.20	2.30	1.90	3.00	1未満
5	7.3	2.0	15.0	21.0	20.0	27.0	7.3	18.0	12.0	23.0	22.0	28.0	1.30	2.30	2.30	2.90	1未満
6	7.2	3.0	15.0	19.0	23.0	21.0	7.0	21.0	17.0	23.0	24.0	22.0	1.70	2.50	2.80	2.20	1未満
7	7.2	5.0	20.0	16.0	21.0	22.0	6.7	28.0	21.0	18.0	22.0	25.0	2.40	2.00	2.70	2.80	1未満
8	7.3	4.0	20.0	17.0	19.0	17.0	6.4	38.0	26.0	17.0	23.0	20.0	3.00	2.00	2.70	2.50	1未満
9	7.3	3.0	18.0	24.0	19.0	18.0	5.3	32.0	24.0	27.0	26.0	24.0	2.60	3.40	3.00	2.90	1未満
10	7.3	3.0	18.0	19.0	18.0	20.0	4.4	34.0	26.0	23.0	25.0	27.0	3.10	3.00	3.00	3.20	1未満
11	7.2	3.0	24.0	21.0	18.0	27.0	6.7	37.0	28.0	23.0	21.0	26.0	3.30	3.80	2.60	2.90	1未満
12	7.3	4.0	25.0	24.0	23.0	24.0	11.0	33.0	27.0	27.0	24.0	26.0	3.00	2.90	3.20	2.90	1未満
1	7.5	3.0	30.0	26.0	26.0	27.0	11.0	38.0	32.0	29.0	33.0	31.0	3.40	3.30	3.70	3.50	1未満
2																	
3																	
平均	7.3	3.2					21.7	7.6	31.3				24.4			2.78	1.0
最大	7.5	5.0					32.0	11.0	38.0				33.0			3.80	1.0
最小	7.2	2.0					15.0	4.4	18.0				12.0			1.30	1.0

余田地区 (流入水質)

月	pH	SS mg/ℓ	COD mg/ℓ	BOD mg/ℓ	T-N mg/ℓ	T-P mg/ℓ
5	7.3	71.0	53.0	65.0	24.0	2.4
8	7.1	120.0	74.0	80.0	35.0	3.4
10	7.2	84.0	61.0	69.0	32.0	3.1
2						
平均	7.2	91.7	62.7	71.3	30.3	3.0
最大	7.3	120.0	74.0	80.0	35.0	3.4
最小	7.1	71.0	53.0	65.0	24.0	2.4

放流基準値		
pH	5.8以上8.6以下	—
SS	50以下	mg/ℓ
COD	40以下	mg/ℓ
BOD	20以下	mg/ℓ
Cl ⁻	—	mg/ℓ
T-N	60以下	mg/ℓ
T-P	8以下	mg/ℓ
大腸菌群数	3000以下	個/mℓ

大貫地区 (放流水質)

令和5年度

月	pH	SS mg/ℓ	COD mg/ℓ				BOD mg/ℓ	Cl ⁻ mg/ℓ	T-N mg/ℓ				T-P mg/ℓ			大腸 個/mℓ		
排水基準値	5.8- 8.6	90 (70)	50 (40)				25 (20)		120 (60)				16 (8)			3000		
4	7.3	3.0	26.0	23.0	24.0	27.0	9.3	35.0	30.0	24.0	22.0	28.0	3.20	2.50	2.50	3.10	1未満	
5	7.3	3.0	18.0	21.0	20.0	23.0	8.6	19.0	15.0	23.0	23.0	28.0	1.70	2.50	2.60	3.00	1未満	
6	7.2	2.0	19.0	21.0	21.0	19.0	12.0	23.0	19.0	27.0	21.0	19.0	2.10	2.80	2.80	2.40	1未満	
7	7.1	4.0	20.0	18.0	20.0	20.0	12.0	30.0	15.0	12.0	14.0	20.0	2.40	2.30	2.80	2.90	1未満	
8	7.3	3.0	22.0	19.0	18.0	16.0	14.0	32.0	19.0	15.0	18.0	17.0	3.00	2.30	2.80	2.80	1未満	
9	7.3	3.0	18.0	20.0	19.0	16.0	14.0	28.0	18.0	18.0	18.0	16.0	2.70	3.00	2.70	2.90	1未満	
10	7.3	3.0	17.0	18.0	18.0	19.0	3.7	30.0	16.0	16.0	15.0	16.0	3.00	2.70	2.70	2.70	1未満	
11	7.2	4.0	20.0	20.0	19.0	21.0	9.2	31.0	23.0	20.0	20.0	23.0	2.90	2.20	2.70	2.70	1未満	
12	7.3	3.0	21.0	22.0	22.0	25.0	5.2	30.0	22.0	24.0	23.0	25.0	2.70	2.80	3.30	2.80	1未満	
1	7.5	3.0	29.0	25.0	24.0	27.0	10.0	33.0	32.0	28.0	29.0	31.0	3.30	3.10	3.20	3.30	1未満	
2																		
3																		
平均	7.3	3.1					20.9	9.8	29.1				21.1				2.75	1.0
最大	7.5	4.0					29.0	14.0	35.0				32.0				3.30	1.0
最小	7.1	2.0					16.0	3.7	19.0				12.0				1.70	1.0

大貫地区 (流入水質)

月	pH	SS mg/ℓ	COD mg/ℓ	BOD mg/ℓ	T-N mg/ℓ	T-P mg/ℓ
5	7.1	97.0	76.0	90.0	31.0	3.2
8	6.9	110.0	86.0	120.0	37.0	4.1
10	7.1	90.0	69.0	74.0	45.0	3.6
2						
平均	7.0	99.0	77.0	94.7	37.7	3.6
最大	7.1	110.0	86.0	120.0	45.0	4.1
最小	6.9	90.0	69.0	74.0	31.0	3.2

放流基準値		
pH	5.8以上8.6以下	—
SS	50以下	mg/ℓ
COD	40以下	mg/ℓ
BOD	20以下	mg/ℓ
Cl ⁻	—	mg/ℓ
T-N	60以下	mg/ℓ
T-P	8以下	mg/ℓ
大腸菌群数	3000以下	個/mℓ

田口地区

(放流水質)

令和5年度

月	pH	SS mg/ℓ	COD mg/ℓ		BOD mg/ℓ	Cl ⁻ mg/ℓ	T-N mg/ℓ		T-P mg/ℓ		大腸 個/mℓ
排水基準値	5.8- 8.6	90 (70)	50 (40)		25 (20)		120 (60)		16 (8)		3000
4	6.9	28.0	25.0	20.0	10.0	36.0	17.0	4.4	3.50	3.70	1未満
5	6.8	4.0	9.4	10.0	4.5	31.0	7.3	6.8	1.30	2.70	1未満
6	6.6	2.0	7.5	6.9	2.7	26.0	1.5	1.6	1.50	3.00	1未満
7	6.7	3.0	6.7	8.2	1.4	34.0	2.8	8.3	3.70	2.90	1未満
8	7.2	5.0	12.0	10.0	3.5	32.0	15.0	8.1	3.70	2.90	1未満
9	6.9	5.0	8.7	8.2	2.4	30.0	4.6	6.6	3.60	4.10	1未満
10	7.0	5.0	9.7	13.0	2.7	31.0	4.3	14.0	2.90	4.80	1未満
11	6.6	5.0	8.3	12.0	2.9	36.0	1.7	9.3	2.90	5.10	1未満
12	7.2	31.0	8.2	7.8	3.3	33.0	33.0	2.5	0.09	0.08	4
1	6.7	4.0	8.3	9.0	3.4	36.0	5.2	5.3	2.20	3.50	7
2											
3											
平均	6.9	9.2		10.4	3.7	32.5		8.0		2.91	1.3
最大	7.2	31.0		25.0	10.0	36.0		33.0		5.10	4.0
最小	6.6	2.0		6.7	1.4	26.0		1.5		0.08	1.0

田口地区

(流入水質)

月	pH	SS mg/ℓ	COD mg/ℓ	BOD mg/ℓ	T-N mg/ℓ	T-P mg/ℓ
5	7.2	47	59.0	63.0	29.0	2.9
8	7.3	93	82.0	150.0	41.0	4.0
10	7.1	130	110.0	120.0	44.0	4.9
2						
平均	7.2	90	83.7	111.0	38.0	3.9
最大	7.3	130	110.0	150.0	44.0	4.9
最小	7.1	47	59.0	63.0	29.0	2.9

放流基準値		
pH	5.8以上8.6以下	—
SS	50以下	mg/ℓ
COD	40以下	mg/ℓ
BOD	20以下	mg/ℓ
Cl ⁻	—	mg/ℓ
T-N	60以下	mg/ℓ
T-P	8以下	mg/ℓ
大腸菌群数	3000以下	個/mℓ

八千種地区

(放流水質)

令和5年度

月	pH	SS mg/ℓ	COD mg/ℓ				BOD mg/ℓ	Cl ⁻ mg/ℓ	T-N mg/ℓ				T-P mg/ℓ			大腸 個/mℓ	
排水基準 値	5.8- 8.6	90 (70)	50 (40)				25 (20)		120 (60)				16 (8)			3000	
4	6.7	4.0	7.8	8.0	8.0	8.5	5.3	35.0	2.6	1.7	1.9	2.5	2.30	1.60	1.60	2.00	1未満
5	6.8	7.0	6.7	8.2	7.4	9.1	4.2	19.0	1.0	1.8	2.1	1.8	0.79	1.60	2.30	1.90	5
6	6.6	4.0	5.5	6.3	5.7	5.9	1.9	23.0	1.1	1.7	1.4	1.5	1.30	2.00	1.90	1.80	1未満
7	6.7	4.0	5.8	6.2	8.9	7.5	2.4	33.0	1.0	0.9	1.7	2.1	1.80	1.80	2.20	2.60	1未満
8	6.7	5.0	7.9	20.0	26.0	10.0	1.6	38.0	1.3	20.0	27.0	1.8	2.80	4.00	4.20	1.00	1未満
9	6.9	4.0	6.6	7.2	8.1	6.2	2.2	34.0	1.3	1.2	3.2	5.4	1.60	2.60	2.20	2.40	1未満
10	6.8	6.0	7.4	6.6	8.2	6.3	1.8	36.0	4.2	1.3	1.3	1.2	2.60	2.10	2.30	2.00	1未満
11	6.6	9.0	8.2	7.1	5.8	6.8	2.7	41.0	1.8	1.4	1.9	1.5	1.80	2.30	1.80	2.00	1未満
12	6.7	6.0	6.7	5.4	6.6	6.0	3.4	36.0	1.6	1.7	1.7	2.1	1.90	1.90	2.30	1.80	1未満
1	6.7	13.0	15.0	7.6	6.8	8.3	6.2	40.0	2.5	1.0	1.4	1.5	2.20	1.70	2.60	2.30	1未満
2																	
3																	
平均	6.7	6.2					8.2	3.2	33.5			2.9				2.10	1.4
最大	6.9	13.0					26.0	6.2	41.0			27.0				4.20	5.0
最小	6.6	4.0					5.4	1.6	19.0			0.9				0.79	1.0

八千種

(流入水質)

月	pH	SS mg/ℓ	COD mg/ℓ	BOD mg/ℓ	T-N mg/ℓ	T-P mg/ℓ
5	7.1	53.0	53.0	67.0	23.0	2.2
8	7.0	110.0	85.0	160.0	37.0	3.6
10	7.0	110.0	95.0	120.0	38.0	3.9
2						
平均	7.0	91.0	77.7	115.7	32.7	3.2
最大	7.1	110.0	95.0	160.0	38.0	3.9
最小	7.0	53.0	53.0	67.0	23.0	2.2

放流基準値		
pH	5.8以上8.6以下	—
SS	50以下	mg/ℓ
COD	40以下	mg/ℓ
BOD	20以下	mg/ℓ
Cl ⁻	—	mg/ℓ
T-N	60以下	mg/ℓ
T-P	8以下	mg/ℓ
大腸菌群数	3000以下	個/mℓ